

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY REGION 7

11201 Renner Boulevard Lenexa, Kansas 66219

JUN 1 3 2016

Mike Moulton Manager MFA Oil Company 821 South Business Highway 13 Lexington, Missouri 64067

RE: SPCC Inspection
MFA Oil Petro Card Station
South 24th Street
Lexington, Missouri

Dear Mr. Moulton:

On or about May 5, 2016, a representative of the U.S. Environmental Protection Agency inspected the unmanned MFA Oil Petro Card Station located in Lexington, Missouri. The inspection was done under the authority of Section 308 of the Clean Water Act, 33 U.S.C. § 1318. A copy of the Spill Prevention Control and Countermeasures Field Inspection and Plan Review Checklist Form is enclosed for your information. Please reference Attachment E for a comprehensive list of comments regarding the facility inspection.

The EPA is presently reviewing the findings of the report to determine your facility's compliance with the applicable statutes and regulations. If it is determined that violations exist, the EPA reserves all rights it may have to take appropriate enforcement action.

If there are any questions regarding this report or actions that you may want to take, please contact Mark Aaron at (913) 551-7205.

Sincerely,

Mark Aaron

Environmental Scientist

Chemical and Oil Release Prevention Branch

Air and Waste Management Division

Enclosure





U.S. ENVIRONMENTAL PROTECTION AGENCY SPCC FIELD INSPECTION AND PLAN REVIEW CHECKLIST

MFA Oil Petro Card Station, Lexington, MO

Overview of the Checklist

This checklist is designed to assist EPA inspectors in conducting a thorough and nationally consistent inspection of a facility's compliance with the Spill Prevention, Control, and Countermeasure (SPCC) rule at 40 CFR part 112. It is a required tool to help federal inspectors (or their contractors) record observations for the site inspection and review of the SPCC Plan. While the checklist is meant to be comprehensive, the inspector should always refer to the SPCC rule in its entirety, the SPCC Regional Inspector Guidance Document, and other relevant guidance for evaluating compliance. This checklist must be completed in order for an inspection to count toward an agency measure (i.e., OEM inspection measures or GPRA). The completed checklist and supporting documentation (i.e. photo logs or additional notes) serve as the inspection report.

This checklist addresses requirements for onshore facilities including Tier II Qualified Facilities (excluding facilities involved in oil drilling, production and workover activities) that meet the eligibility criteria set forth in §112.3(g)(2).

Qualified facilities must meet the rule requirements in §112.6 and other applicable sections specified in §112.6, except for deviations that provide environmental equivalence and secondary containment impracticability determinations as allowed under §112.6.

The checklist is organized according to the SPCC rule. Each item in the checklist identifies the relevant section and paragraph in 40 CFR part 112 where that requirement is stated.

- Sections 112.1 through 112.5 specify the applicability of the rule and requirements for the preparation, implementation, and amendment of SPCC Plans. For these sections, the checklist includes data fields to be completed, as well as several questions with "yes," "no" or "NA" answers.
- Section 112.6 includes requirements for qualified facilities. These provisions are addressed in Attachment D.
- Section 112.7 includes general requirements that apply to all facilities (unless otherwise excluded).
- Sections 112.8 and 112.12 specify requirements for spill prevention, control, and countermeasures for onshore facilities (excluding production facilities).

The inspector needs to evaluate whether the requirement is addressed adequately or inadequately in the SPCC Plan and whether it is implemented adequately in the field (either by field observation or record review). For the SPCC Plan and implementation in the field, if a requirement is addressed adequately, mark the "Yes" box in the appropriate column. If a requirement is not addressed adequately, mark the "No" box. If a requirement does not apply to the particular facility or the question asked is not appropriate for the facility, mark as "NA". Discrepancies or descriptions of inspector interpretation of "No" vs. "NA" may be documented in the comments box subsequent to each section. If a provision of the rule applies only to the SPCC Plan, the "Field" column is shaded.

Space is provided throughout the checklist to record comments. Additional space is available as Attachment E at the end of the checklist. Comments should remain factual and support the evaluation of compliance.

Attachments

- Attachment A is for recording information about containers and other locations at the facility that require secondary containment.
- Attachment B is a checklist for documentation of the tests and inspections the facility operator is required to keep with the SPCC Plan.
- Attachment C is a checklist for oil spill contingency plans following 40 CFR 109. Unless a facility has submitted a Facility Response Plan (FRP) under 40 CFR 112.20, a contingency plan following 40 CFR 109 is required if a facility determines that secondary containment is impracticable as provided in 40 CFR 112.7(d). The same requirement for an oil spill contingency plan applies to the owner or operator of a facility with qualified oil-filled operational equipment that chooses to implement alternative requirements instead of general secondary containment requirements as provided in 40 CFR 112.7(k).
- Attachment D is a checklist for Tier II Qualified Facilities.
- Attachment E is for recording additional comments or notes.
- Attachment F is for recording information about photos.

FACILITY INFORMATION						
FACILITY NAME: MFA Oil Petro Card	Station	ETA, THE THE	2 2 9 2 1 7 3	-		
LATITUDE: 39.1787°	LONGITUD	E: -93.85299°	51. 1	GPS	DATUM: WO	GS84
Section/Township/Range: NE1/4, S34,	T51N, R27W	FRS#/OIL DA	TABASE ID:		3	ICIS#:
ADDRESS: South 24th Street					1	7 (1) (1) (1) (1) (1) (1) (1) (1
CITY: Lexington	STATE: N	МО	ZIP: 64067	1	Co	OUNTY: Lafayette
MAILING ADDRESS (IF DIFFERENT FROM F	ACILITY ADDRESS	- IF NOT, PRINT "SAME"): same			
CITY:	STATE:	1.1	ZIP:		C	OUNTY:
TELEPHONE: 660-259-3687	FAC	ILITY CONTACT	Γ NAME/TITL	E: Mi	ke Moulton, M	lanager
OWNER NAME: MFA Oil Company						te de
OWNER ADDRESS: One Ray Young	Drive				and the second second	
CITY: Columbia	STATE:	MO	ZIP: 65205		С	OUNTY: Boone
TELEPHONE: 573-641-2063	FAX	: '	10.0		EMAIL:	
FACILITY OPERATOR NAME (IF DIFFEI	RENT FROM OWNE	R - IF NOT, PRINT "SAM	E*): same		1	
OPERATOR ADDRESS:					-6	
CITY:	STATE:		ZIP:		C	COUNTY:
TELEPHONE:	OPI	ERATOR CONTA	CT NAME/TI	TLE:	1	
FACILITY TYPE: bulk oil storage and	sales			-	s	IC CODE:
HOURS PER DAY FACILITY ATTENI	DED: 24-hours	s/day	TOTAL FAC	CILITY	Y CAPACITY:	30,000 gallons
TYPE(S) OF OIL STORED: diesel, ga	soline, and m	otor oil and lubric	ants			
LOCATED IN INDIAN COUNTRY?	YES IN	O RESERVATION	ON NAME:			
INSPECTION/PLAN REVIEW INF	ORMATION					
PLAN REVIEW DATE: April 12, 2016	RI	EVIEWER NAME	: Paul Dohert	ty		
INSPECTION DATE: May 5, 2016	ТІ	ME: 10:30 AM	ACTIVI	TY ID	NO:	
LEAD INSPECTOR: Paul Doherty					- Sie	
OTHER INSPECTOR(S): Jeff Pritch	ard, EPA	Zidas an i	0	266	P	5-30-16
INSPECTION ACKNOWLEDGME	ENT					
I performed an SPCC inspection at the	e facility spec	ified above.	, E			· Alastie
INSPECTORS SIGNATURES:	经	Jules			1	DATE: = /30/16
SUPERVISOR REVIEW/SIGNATURE	I R	0				DATE: 5/31/16

SPCC GENERAL APPLICABILITY—40 CFR 112.1			
IS THE FACILITY REGULATED UNDER 40 CFR part 112?	Partie of seasons as described in \$412. If the earth season process as easier in a U.S. I		
The completely buried oil storage capacity is over 42,000 U.S. galloil storage capacity is over 1,320 U.S. gallons AND			
The facility is a non-transportation-related facility engaged in drillin processing, refining, transferring, distributing, using, or consuming location could reasonably be expected to discharge oil into or upor States	g, producing, gathering, storing, oil and oil products, which due to its		
AFFECTED WATERWAY(S): Surface drainage to unnamed creek that Lick Fork and then flows to Tabo Creek	t drains to DISTANCE: 200 feet to surface drainage		
FLOW PATH TO WATERWAY: Surface drainage to unnamed creek t	o Lick Fork to Tabo Creek 1400×1910 Hillory 31 ST		
Note: The following storage capacity is not considered in determining applicabili			
 Equipment subject to the authority of the U.S. Department of Transportation, U.S. Department of the Interior, or Minerals 	· Containers smaller than 55 U.S. gallons;		
Management Service, as defined in Memoranda of Understanding dated	· Permanently closed containers (as defined in §112.2);		
November 24, 1971, and November 8, 1993; Tank trucks that return to an otherwise regulated facility that contain only residual amounts of oil	 Motive power containers (as defined in §112.2); 		
(EPA Policy letter)	 Hot-mix asphalt or any hot-mix asphalt containers; 		
Completely buried tanks subject to all the technical requirements of 40 CFR part 280 or a state program approved under 40 CFR part 281;	· Heating oil containers used solely at a single-family residence;		
· Underground oil storage tanks deferred under 40 CFR part 280 that	· Pesticide application equipment and related mix containers;		
supply emergency diesel generators at a nuclear power generation facility licensed by the Nuclear Regulatory Commission (NRC) and subject to any NRC provision regarding design and quality criteria,	· Any milk and milk product container and associated piping and appurtenances; and		
including but not limited to CFR part 50;	 Intra-facility gathering lines subject to the regulatory requirements of 49 CFR part 192 or 195. 		
 Any facility or part thereof used exclusively for wastewater treatment (production, recovery or recycling of oil is not considered wastewater treatment); (This does not include other oil containers located at a wastewater treatment facility, such as generator tanks or transformers) 	01 49 CFR pair 192 01 195.		
Does the facility have an SPCC Plan?	rendan be ver data secretaria sua a la parte de Yes Di No		
FACILITY RESPONSE PLAN (FRP) APPLICABILITY—40 CF	R 112.20(f)		
A non-transportation related onshore facility is required to prepare and	implement an FRP as outlined in 40 CFR 112.20 if:		
The facility transfers oil over water to or from vessels and has 42,000 U.S. gallons, <u>OR</u>	[전시] 전 [1] [1] [1] [1] [1] [1] [1] [1] [1] [1]		
☐ The facility has a total oil storage capacity of at least 1 million	U.S. gallons, AND at least one of the following is true:		
The facility does not have secondary containment su tank plus sufficient freeboard for precipitation.	ifficiently large to contain the capacity of the largest aboveground		
The facility is located at a distance such that a discharge environments.	arge could cause injury to fish and wildlife and sensitive		
The facility is located such that a discharge would sh	nut down a public drinking water intake.		
The facility has had a reportable discharge greater the	nan or equal to 10,000 U.S. gallons in the past 5 years.		
Facility has FRP: ☐ Yes ☐ No ☑ NA	FRP Number:		
Facility has a completed and signed copy of Appendix C, Attachment Certification of the Applicability of the Substantial Harm Criteria."	C-II, Yes Yes No		
Comments: The facility is a wholesale distributor and retail merchant with a total storage capacity of 30,000 gallons. In addition, there are	t of petroleum products. There are 3 aboveground storage tanks a number of 55-gal drums in a warehouse.		
SPCC TIER II QUALIFIED FACILITY APPLICABILITY—40 C	FR 112.3(g)(2)		
The aggregate aboveground oil storage capacity is 10,000 U.S. gallor	ns or less AND		
In the three years prior to the SPCC Plan self-certification date, or sin			

Production of the second of th

15 10 12 5 C11 136 April 1, 552 K V1552		ed in §112.1(b) exceeding 1,000 in §112.1(b) each exceeding 42			☐ Yes ☑ No ☐ Yes ☑ No
	IF YES TO	ALL OF THE ABOVE, THEN THE SEE ATTACHMENT DIFOR TIE	HE FACILITY IS A TIEF	R II QUALIFIED FACILI	THE PERSON NAMED IN COLUMN TO PERSON NAMED I
REQUIREMEN	ITS FOR PRE	PARATION AND IMPLEMEN	TATION OF A SPC	C PLAN—40 CFR 11	2.3
Date facility bega operation as far		he date the facility began operat	ions is unknown. Aeria	al photographs indicate	the facility was in
Date of initial SP	CC Plan prepar	ation: Unknown Curre	ent Plan version (date/n	number): October 2011	1 1947 - 1 1941
112.3(a)	For facilities (e In operation implement Beginning before beginning	☑Yes ☐No ☐NA ☐Yes ☐No ☑NA			
	For farms (as In operation implement Beginning fully impleted Beginning	defined in §112.2): on on or prior to August 16, 2002 ted by May 10, 2013 operations after August 16, 2003 mented by May 10, 2013 operations after May 10, 2013: Forest	; Plan maintained, ame 2 through May 10, 2013	3: Plan prepared and	□Yes □No ☑NA □Yes □No ☑NA □Yes □No ☑NA
112.3(d)	Plan is certified PE attests: PE is fam PE or age Plan is pr of applica Procedure	I by a registered Professional English with the requirements of 40 Cent has visited and examined the epared in accordance with good ble industry standards and the rest for required inspections and teleguate for the facility	CFR part 112 facility engineering practice incurrements of 40 CFR	cluding consideration part 112	Yes
PE Name: Duar	ne Ottmar	License No.: E-24241	State: MO	Date of certification	and the desired and the second of the second
112.3(e)(1)	available at t	ble onsite if attended at least 4 h ne nearest field office. nearest field office contact inform	record was a dis-	ada nos en	☑Yes ☐No ☐NA
Comments: The 13472 East High		n statement adequately addresse ngton, Missouri.		The plan is available at	200
AMENDMENT	OF SPCC PL	AN BY REGIONAL ADMINIS		SALSANDA DE LA CONTRACTOR DEL CONTRACTOR DE LA CONTRACTOR DE LA CONTRACTOR DE LA CONTRACTOR	
112.4(a),(c) If YES	Was information with the was information pollution.	discharged more than 1,000 U.S. 2 U.S. gallons in each of two rep mation submitted to the RA as remation submitted to the appropri control activities in the State in wind volume(s) of reportable discharge.	ortable discharges in a equired in §112.4(a)? ³ ate agency or agencies hich the facility is locate	ny 12-month period? ² s in charge of oil ed§112.4(c)	Yes No No NA Yes No No NA
	Were the	discharges reported to the NRC	4?	Barri Bara Green va	Yes No
112.4(d),(e)	Have changes	required by the RA been implem	nented in the Plan and/o	or facility?	☐ Yes ☐ No ☑ NA

⁴ Inspector Note-Confirm any spills identified above were reported to NRC

¹ An owner/operator who self-certifies a Tier II SPCC Plan may include environmentally equivalent alternatives and/or secondary containment impracticability determinations when reviewed and certified by a PE.

² A reportable discharge is a discharge as described in §112.1(b)(see 40 CFR part 110). The gallon amount(s) specified (either 1,000 or 42) refers to the amount of oil that actually reaches navigable waters or adjoining shorelines not the total amount of oil spilled. The entire volume of the discharge is oil for this determination.

³ Triggering this threshold may disqualify the facility from meeting the Qualified Facility criteria if it occurred in the three years prior to self certification

Comments: Th	e plan does not add	ress the spill history of	the facility. No amendments	were made as a result	of a prior spill.
AMENDMENT	OF SPCC PLAN	BY THE OWNER OR	OPERATOR-40 CFR 1	12.5	
112.5(a)	Has there been a change at the facility that materially affects the potential for a discharge described in §112.1(b)?			☐Yes ☑ No	
If YES	 Was the Plan amended within six months of the change? Were amendments implemented within six months of any Plan amendment? 			☐Yes ☐ No ☐Yes ☐ No	
112.5(b)		10	ed at least once every 5 yea	H Inchie	Yes DNo DNA
	Following Plan revieus prevention and con likelihood of a disch	ew, was Plan amended trol technology that has arge described in §112	within six months to include been field-proven to signific .1(b)?	more effective	Yes DNo DNA
96.00			ns of any Plan amendment?		Yes DNo DNA
7 - CLOS VI. 13 VI. 15 VII. 15 V	AND RESIDENCE OF THE PARTY OF T	ew and evaluation docu		E Note that the	Yes DNo DNA
			echnical Plan amendments in ept for self-certified Plans]	n accordance with all	Yes IINO IINA
Name:		License No.:	State:	Date of certification:	
October 2016.			riodic SPCC review and ame	endments. The plan is no	ot due for review until
13 900 7 500 3470 530		NTS-40 CFR 112.7		Service and the service of the service of the service of	FIELD
Management ap fully implement		authority to commit the	necessary resources to	☑Yes ☐No	
		r is an equivalent Plan n reference of provisions	neeting all applicable rule	☑Yes ☐No ☐NA	
details of their in	facilities, procedure nstallation and start- testing baselines.)	s, methods, or equipme up are discussed <i>(Note</i>	nt not yet fully operational, : Relevant for inspection	□Yes □No 図NA	
112.7(a)(2)	(h)(2) and (3), and except the second (h)(1), 112.8(c)(2)	(i) and applicable subp	7 7 7 7 7	□Yes ☑No □NA □Yes □No ☑NA	
	environmenta the environme	I protection (Note: Inspe	etail and provide equivalent ector should document if olemented in the field, in on)	☐Yes ☐No ☑NA	☐Yes ☐No ☐NA
Describe each described in the		ns for nonconformance	There is no statement of	deviation or reasons for	nonconformance
112.7(a)(3)	that identifies:	nysical layout of facility a	and includes a diagram ⁶	☑Yes ☐No	☑Yes ☐No
		here mobile or portable co			- 1 hr
	(marked as "exe	empt")	t from the SPCC requirements		1
	Transfer station Connecting pine	s es, including intra-facility ga	athering lines that are		
	otherwise exem	pt from the requirements of	of this part under §112.1(d)(11)		Fig. 10, Special
	Plan addresses	each of the following:			

⁵ May be part of the Plan or demonstrated elsewhere.

⁶ Note in comments any discrepancies between the facility diagram, the description of the physical layout of facility, and what is observed in the field

(i)	For each fixed container, type of oil and storage capacity (see	Yes DNo	☑Yes ☐No
	Attachment A of this checklist). For mobile or portable containers, type of oil and storage capacity for each container or an estimate of the potential number of mobile or portable containers, the types of oil, and anticipated storage capacities	STATE NAME OF STREET	n do leng til førdi. som i delt d
(ii)	Discharge prevention measures, including procedures for routine handling of products (loading, unloading, and facility transfers, etc.)	Yes No	☑Yes ☐No
(iii)	Discharge or drainage controls, such as secondary containment around containers, and other structures, equipment, and procedures for the control of a discharge	Yes INo	☑Yes ☐No
(iv)	Countermeasures for discharge discovery, response, and cleanup (both facility's and contractor's resources)	☑Yes ☐No	☑Yes ☐No
(v)	Methods of disposal of recovered materials in accordance with applicable legal requirements	Yes No	
(vi)	Contact list and phone numbers for the facility response coordinator, National Response Center, cleanup contractors with an agreement for response, and all Federal, State, and local agencies who must be contacted in the case of a discharge as described in §112.1(b)	☑Yes ☐No	
112.7(a)(4)	Does not apply if the facility has submitted an FRP under §112.20:	MYes INO INA	
	Plan includes information and procedures that enable a person report an oil discharge as described in §112.1(b) to relate information on the:	ing	
	 Exact address or location and phone number of the facility; Date and time of the discharge; Type of material discharged, Estimates of the quantity discharged as Description of all aff Cause of the discharge Damages or injuries Actions being used mitigate the effects of Whether an evacual 	arge; s caused by the discharge; to stop, remove, and if the discharge; tion may be needed, and ls and/or organizations who	
112.7(a)(5)	Does not apply if the facility has submitted a FRP under §112.20: Plan organized so that portions describing procedures to be used when a discharge occurs will be readily usable in an emergency	MYes □No □NA	
112.7(b)	Plan includes a prediction of the direction, rate of flow, and total quantity of oil that could be discharged for each type of major equipment failure where experience indicates a reasonable potential for equipment failure	☑Yes ☐No ☐NA	
	the plan does not address the dispenser island as a loading/unloading a re located in the facility building which meets the requirements for gene		
112.7(c)	2,000 gr 4 gg 1000 mag	are provided to prevent and qualified operational equining oil and are constructed method, design, and cap	a discharge as described uipment. The entire ted to prevent escape of pacity for secondary
	the first term of the first te	9 1 1	
	Identify which of the following are present at the facility and if appropequipment are provided as described above:	riate containment and/or	diversionary structures or
	☑ Bulk storage containers	☑Yes ☐No ☐NA	Yes ONO ONA
	☑ Mobile/portable containers	Yes DNo DNA	Yes ONO ONA
	Oil-filled operational equipment (as defined in 112.2)	☐Yes ☐No ☑NA	Yes No MA
	Other oil-filled equipment (i.e., manufacturing equipment)	☐Yes ☐No ☑NA	A ☐ Yes ☐ No ☑ NA
	☑ Piping and related appurtenances	☑Yes ☐No ☐NA	Yes ONO ONA

	Mobile refuelers or non-transpo	rtation-related tank cars	☐ Yes	ПNо	☑ NA	DYes DNo	. ☑NA
11.00	Transfer areas, equipment and		Yes	ПNо	DNA	☑ Yes ☐ No	DNA
1000	Identify any other equipment or above:	activities that are not listed	ПYes	ΠNo	☑NA	□Yes□No	. ☑NA
112.7(d)	Secondary containment for one (or is determined to be impracticable:	more) of the following provisions	[] Yes	☑ No	, li		
9.747.25	General secondary containment §112.7(c)	Bulk storage containers §§112.8(c)(2)/112.12(c)(2)	edic on		183 1174 134		
_3	Loading/unloading rack §112.7(h)(1)	Mobile/portable containers §§112.8(c)(11)/ 112.12(c)(11)			1 H = 18		
If YES	The impracticability of seconda demonstrated and described in	ry containment is clearly the Plan	[] Yes	Пио	MNA	П Yes П No	o ⊠ NA
. N	 For bulk storage containers,⁷ p containers and integrity and lea and piping is conducted 	eriodic integrity testing of ak testing of the associated valves	Yes	ПNо	⊠ NA	L Yes L No	o ☑NA
	(Does not apply if the facility has subm		☐ Yes	ПNо	MA		
	 Contingency Plan following the provided (see Attachment C of 	provisions of 40 CFR part 109 is this checklist) AND					
	 Written commitment of manpoor required to expeditiously control discharged that may be harmful 	ol and remove any quantity of oil	El Yes	ПNо	Ø NA	ПYesПN	o ⊠na
containers is pro	e SPCC plan does not make an improvided by containment dikes. Drums land as a loading/unloading area. He provisionment for general secondary	are reportedly within containment owever, spill equipment/materials (in the wa	rehous	e. The p	lan does not ac	ddress
containers is pro	ovided by containment dikes. Drums	are reportedly within containment owever, spill equipment/materials (in the wa	rehous its) are	e. The p	lan does not ac	ddress
containers is pro the dispenser is which meets the	ovided by containment dikes. Drums land as a loading/unloading area. He requirements for general secondar	s are reportedly within containment owever, spill equipment/materials (y containment.	in the war	rehouse its) are PLAN	e. The p located i	lan does not ac n the facility bu	ilding D
containers is pro	ovided by containment dikes. Drums land as a loading/unloading area. H	s are reportedly within containment owever, spill equipment/materials (y containment.	in the wa	rehouse its) are PLAN	e. The p located i	lan does not ac n the facility bu	ilding D
containers is pro the dispenser is which meets the	Inspections and tests conducted in procedures Record of inspections or tests sign	s are reportedly within containment owever, spill equipment/materials (y containment. accordance with written ed by supervisor or inspector	in the war	PLAN	e. The p located i	lan does not ac n the facility bu	illding D
containers is pro the dispenser is which meets the	ovided by containment dikes. Drums land as a loading/unloading area. He requirements for general secondary lnspections and tests conducted in procedures	s are reportedly within containment owever, spill equipment/materials (y containment. accordance with written ed by supervisor or inspector	in the war (absorben	PLAN	e. The p located i	lan does not ac n the facility bu FIEL ☐ Yes ☑ N	ilding D lo
containers is pro the dispenser is which meets the	Inspections and tests conducted in procedures Record of inspections or tests sign Kept with Plan for at least 3 years	s are reportedly within containment owever, spill equipment/materials (y containment. accordance with written ed by supervisor or inspector (see Attachment B of this	in the war (absorben	PLAN	e. The p located i	FIEL Yes ☑ N	ilding D lo
containers is prothe dispenser is which meets the	Inspections and tests conducted in procedures Record of inspections or tests sign Kept with Plan for at least 3 years checklist) ⁸	s are reportedly within containment owever, spill equipment/materials (y containment. accordance with written ed by supervisor or inspector (see Attachment B of this rge prevention procedures in operation and maintenance of discharge procedure protocols; ules, and regulations; general	in the war (absorben ☑ Yes ☑ Yes ☑ Yes	PLAN No No	e. The p located i	FIEL Yes ☑ N Yes ☑ N	D lo lo
containers is prothed dispenser is which meets the 112.7(e)	Inspections and tests conducted in procedures Record of inspections or tests sign Kept with Plan for at least 3 years checklist) ⁸ Personnel, training, and oil dischard Training of oil-handling personnel equipment to prevent discharges; applicable pollution control laws, researched.	s are reportedly within containment owever, spill equipment/materials (y containment. accordance with written ed by supervisor or inspector (see Attachment B of this rge prevention procedures in operation and maintenance of discharge procedure protocols; ules, and regulations; general SPCC Plan e for discharge prevention at the	in the war (absorben ☑ Yes ☑ Yes ☑ Yes ☑ Yes	PLAN PLAN No No	e. The p located i	Ilan does not ac n the facility bu FIEL Yes N Yes N Yes N Yes N	D lo lo lo lo lo NA
containers is prothe dispenser is which meets the shift of the shift o	Inspections and tests conducted in procedures Record of inspections or tests sign Kept with Plan for at least 3 years checklist) ⁸ Personnel, training, and oil dischar Training of oil-handling personnel equipment to prevent discharges; applicable pollution control laws, rifacility operations; and contents of Person designated as accountable	s are reportedly within containment owever, spill equipment/materials (y containment.) accordance with written ed by supervisor or inspector (see Attachment B of this rge prevention procedures in operation and maintenance of discharge procedure protocols; ules, and regulations; general SPCC Plan e for discharge prevention at the gement inducted at least once a year for oil quate understanding of the Plan. Hown discharges as described in an gomponents, and any recently	in the war (absorben de la sorben de la sor	PLAN PLAN No No No No No No No No No	e. The p located i	Ilan does not ac not he facility but the facility but FIEL Yes IN N Yes IN N Yes IN MYes IN MY	D D D D D D D D D D D D D D D D D D D
containers is prothe dispenser is which meets the shift of the shift o	Inspections and tests conducted in procedures Record of inspections or tests sign Kept with Plan for at least 3 years checklist) ⁸ Personnel, training, and oil dischart Training of oil-handling personnel equipment to prevent discharges; applicable pollution control laws, refacility operations; and contents of Person designated as accountable facility and reports to facility mana Discharge prevention briefings conhandling personnel to assure adea Briefings highlight and describe krefully 10 person designated as accountable facility and reports to facility mana Discharge prevention briefings conhandling personnel to assure adea Briefings highlight and describe krefully 10 person designated as accountable facility and reports to facility mana Discharge prevention briefings conhandling personnel to assure adea Briefings highlight and describe krefully 10 person developed precautionary measure Plan describes how to:	s are reportedly within containment owever, spill equipment/materials (y containment.) accordance with written ed by supervisor or inspector (see Attachment B of this rge prevention procedures in operation and maintenance of discharge procedure protocols; ules, and regulations; general SPCC Plan e for discharge prevention at the gement inducted at least once a year for oil quate understanding of the Plan. Hown discharges as described in an gomponents, and any recently	in the war (absorben (abs	PLAN PLAN No No No No No No No No No	DINA DINA DINA	Ilan does not acon the facility but the facility but FIEL Yes IN N Yes IN N Yes IN I Yes I YE	D Io Io Io Io Io Io Io Io Io I

⁷ These additional requirements apply only to bulk storage containers, when an impracticability determination has been made by the PE ⁸ Records of inspections and tests kept under usual and customary business practices will suffice

112.7(h)	Tank car and tank truck loading/unloading rack ⁹ is present at the facility Loading/unloading rack means a fixed structure (such as a platform, gangway) car, which is located at a facility subject to the requirements of this part. A loading and may include any combination of the following: piping assemblages, valves, safety devices.	necessary for loading or unlong/ ng/unloading rack includes a	loading or unloading arm,
If YES (1)	Does loading/unloading rack drainage flow to catchment basin or treatment facility designed to handle discharges or use a quick drainage system?	☐Yes ☐No ☒NA	□Yes□No ☑NA
	Containment system holds at least the maximum capacity of the largest single compartment of a tank car/truck loaded/unloaded at the facility	Пуез Пио Виа	П Yes П № № NA
(2)	An interlocked warning light or physical barriers, warning signs, wheel chocks, or vehicle brake interlock system in the area adjacent to the loading or unloading rack to prevent vehicles from departing before complete disconnection of flexible or fixed oil transfer lines	☐Yes ☐No ☑NA	☐Yes ☐No ☑NA
(3)	Lower-most drains and all outlets on tank cars/trucks inspected prior to filling/departure, and, if necessary ensure that they are tightened, adjusted, or replaced to prevent liquid discharge while in transit	☐Yes ☐No ☑NA	☑Yes ☐No ☑NA
procedures are	ere is not a loading rack at the facility. The inspection program adequate adequate. Load-in and load-out procedures are adequately described a secondary drainage inspection protocol. Secondary drainage logs were that time.	and meet the requiremen	ts of 112.7(h). The
		PLAN	FIELD
112.7(i)	Brittle fracture evaluation of field-constructed aboveground containers is conducted after tank repair, alteration, reconstruction, or change in service that might affect the risk of a discharge or after a discharge/failure due to brittle fracture or other catastrophe, and appropriate action taken as necessary (applies to only field-constructed aboveground containers)	☐Yes ☐No ☑NA	☐Yes ☐No ☑NA
112.7(j)	Discussion of conformance with applicable more stringent State rules, regulations, and guidelines and other effective discharge prevention and containment procedures listed in 40 CFR part 112		
112.7(k)	Qualified oil-filled operational equipment is present at the facility ¹⁰ Oil-filled operational equipment means equipment that includes an oil storage of present solely to support the function of the apparatus or the device. Oil-filled of container, and does not include oil-filled manufacturing equipment (flow-throug equipment include, but are not limited to, hydraulic systems, lubricating system rotating equipment, including pumpjack lubrication systems), gear boxes, mach transformers, circuit breakers, electrical switches, and other systems containing Check which apply: Secondary Containment provided in accordance with 112.7(c) Alternative measure described below (confirm eligibility)	operational equipment is not th process). Examples of oil- is (e.g., those for pumps, con hining coolant systems, heat	considered a bulk storage filled operational mpressors and other transfer systems.
		Lud	PERSONAL PROPERTY.
112.7(k)	 Qualified Oil-Filled Operational Equipment Has a single reportable discharge as described in §112.1(b) from operational equipment exceeding 1,000 U.S. gallons occurred with prior to Plan certification date? 	thin the three years	☐Yes ☐No ☑NA
	 Have two reportable discharges as described in §112.1(b) from a operational equipment each exceeding 42 U.S. gallons occurred period within the three years prior to Plan certification date?¹¹ 	ny oil-filled within any 12-month	☐Yes ☐No ☑NA
	If YES for either, secondary containment in accord	dance with §112.7(c) is re	quired
	Facility procedure for inspections or monitoring program to detect equipment failure and/or a discharge is established and documented	Yes No NA	☐Yes ☑No ☐NA
	100000000000000000000000000000000000000	The state of the s	

⁹ Note that a tank car/truck loading/unloading rack must be present for §112.7(h) to apply

¹⁰ This provision does not apply to oil-filled manufacturing equipment (flow-through process)
11 Oil discharges that result from natural disasters, acts of war, or terrorism are not included in this determination. The gallon amount(s) specified (either 1,000 or 42) refers to the amount of oil that actually reaches navigable waters or adjoining shorelines not the total amount of oil spilled. The entire volume of the discharge is oil for this determination.

	Does not apply if the facility has submitted a FRP under §112.20: Contingency plan following 40 CFR part 109 (see Attachment C of this checklist) is provided in Plan AND Written commitment of manpower, equipment, and materials required to expeditiously control and remove any quantity of oil discharged that may be harmful is provided in Plan	☐Yes ☑No ☐NA☐Yes ☑No ☐NA☐	
Comments: T	here are no field erected tanks on-site. There is no oil-filled equipment	ton site.	100 July 19 19 19 19 19 19 19 19 19 19 19 19 19
	ACILITIES (EXCLUDING PRODUCTION)	PLAN	FIELD
112.8(b)/ 112.12	2(b) Facility Drainage	THE STREET WITE PROPERTY OF	ingga-ya Tilik
Diked Areas	Drainage from diked storage areas is:	Yes DNo DNA	Yes INO INA
(1)	Restrained by valves, except where facility systems are designed to control such discharge, <u>OR</u>	1.11 - F - 100 - 11.1 75 4	ton activity
	 Manually activated pumps or ejectors are used and the condition of the accumulation is inspected prior to draining dike to ensure no oil will be discharged 	2 press	Grant
(2)	Diked storage area drain valves are manual, open-and-closed design (not flapper-type drain valves)	Ø Yes □No □NA	Yes INO INA
Bress ggr	If drainage is released directly to a watercourse and not into an onsite wastewater treatment plant, retained storm water is inspected and discharged per §§112.8(c)(3)(ii), (iii), and (iv) or §§112.12(c)(3)(ii), (iii), and (iv).	☑Yes ☐No ☐NA	☐Yes ☑No ☐NA
Undiked Areas (3)	Drainage from undiked areas with a potential for discharge designed to flow into ponds, lagoons, or catchment basins to retain oil or return it to facility. Catchment basin located away from flood areas. 12	□Yes ☑No □NA	☐Yes ☑No ☐NA
(4)	If facility drainage not engineered as in (b)(3) (i.e., drainage flows into ponds, lagoons, or catchment basins) then the facility is equipped with a diversion system to retain oil in the facility in the event of an uncontrolled discharge. ¹³	☐Yes ☑No ☐NA	Yes No NA
(5)	Are facility drainage waters continuously treated in more than one treatment unit and pump transfer is needed?	Пуев Упо Ппа	ПYes 🗹 No ПNA
If YES	Two "lift" pumps available and at least one permanently installed	□Yes □No ☑NA	Tayross St
72131	 Facility drainage systems engineered to prevent a discharge as described in §112.1(b) in the case of equipment failure or human error 	□Yes □No ☑NA	□Yes □No 図NA
loading/unload requirements for	There is a loading area and dispensing pumps on site. The plan does not ing area. However, spill equipment/materials (absorbents) are located in or general secondary containment. The plan discusses secondary draing lable through May 2015 but no records are available since that time.	the facility building which	n meets the
Bulk storage prior to use, v storage conta	2(c) Bulk Storage Containers container means any container used to store oil. These containers are used for puthile being used, or prior to further distribution in commerce. Oil-filled electrical, or ainer. e containers are not present, mark this section Not Applicable (NA). If present, co	perating, or manufacturing e	quipment is not a bulk
(1)	Containers materials and construction are compatible with material stored and conditions of storage such as pressure and temperature	Yes ONO ONA	☑Yes ☐No ☐NA
(2	Except for mobile refuelers and other non-transportation-related tank trucks, construct all bulk storage tank installations with secondary containment to hold capacity of largest container and sufficient freeboard for precipitation	☑Yes ☐No ☐NA	✓ Yes ☐ No ☐ NA
· + £	Diked areas sufficiently impervious to contain discharged oil OR	☑Yes ☐No ☐NA	☑Yes ☐No ☐NA
175.44	Alternatively, any discharge to a drainage trench system will be safely confined in a facility catchment basin or holding pond.	☑Yes ☐No ☐NA	Yes DNo DNA

¹² Oil discharges that result from natural disasters, acts of war, or terrorism are not included in this determination. The gallon amount(s) specified (either 1,000 or 42) refers to the amount of oil that actually reaches navigable waters or adjoining shorelines not the total amount of oil spilled. The entire volume of the discharge is oil for this determination.

13 These provisions apply only when a facility drainage system is used for containment; otherwise mark NA

		PLAN	FIELD
(3)	Is there drainage of uncontaminated rainwater from diked areas into a storm drain or open watercourse?	Yes INO INA	Уев Пио Пиа
If YES	Bypass valve normally sealed closed	Yes INO INA	Yes DNo DNA
	 Retained rainwater is inspected to ensure that its presence will not cause a discharge as described in §112.1(b) 		У Yes ПNо ПNA
	Bypass valve opened and resealed under responsible supervision	Yes ONO ONA	Yes I No I NA
Q AILL	 Adequate records of drainage are kept; for example, records required under permits issued in accordance with 40 CFR §§122.41(j)(2) and (m)(3) 	Yes INO INA	□Yes ☑No □NA
(4)	For completely buried metallic tanks installed on or after January 10, 1974 (if not exempt from SPCC regulation because subject to all of the technical requirements of 40 CFR part 280 or 281):	en europe en en en en Littuar en la litte en	error
	 Provide corrosion protection with coatings or cathodic protection compatible with local soil conditions 	□Yes □No ☑NA	□Yes □No ☑NA
	Regular leak testing conducted	□Yes □No ☑NA	Пуез Пио MNA
(5)	The buried section of partially buried or bunkered metallic tanks protected from corrosion with coatings or cathodic protection compatible with local soil conditions	□Yes □No ☑NA	☐Yes ☐No ☑NA
(6)	Test or inspect each aboveground container for integrity on a regular schedule and whenever you make material repairs. Techniques include, but are not limited to: visual inspection, hydrostatic testing, radiographic testing, ultrasonic testing, acoustic emissions testing, or other system of non-destructive testing.	Yes QNo QNA	☐Yes ☑No ☐NA
	 Appropriate qualifications for personnel performing tests and inspections are identified in the Plan and have been assessed in accordance with industry standards 	Yes INO INA	□Yes ☑No □NA
. 46	The frequency and type of testing and inspections are documented, are in accordance with industry standards and take into account the container size, configuration and design	☑Yes ☐No ☐NA	Yes I No I NA
4111	Comparison records of aboveground container integrity testing are maintained	☑Yes ☐No ☐NA	Yes DNo DNA
	Container supports and foundations regularly inspected	☑Yes ☐No ☐NA	Yes ONO ONA
20	Outside of containers frequently inspected for signs of deterioration, discharges, or accumulation of oil inside diked areas	☑Yes ☐No ☐NA	☑Yes ☐No ☐NA
	Records of all inspections and tests maintained 14	☑Yes ☐No ☐NA	☑Yes ☐No ☐NA
Integrity Testing details regarding	Standard identified in the Plan: There are no buried tanks on site. Tang the type and timing of tests are provided in Attachment C.	k integrity testing is discussion	ssed in the plan but no
(Applies to		☐ Yes ☐ No ☑ NA	☐ Yes ☐ No ☑ NA
AFVO Facilities only)	That's no external modulation, and		
	In addition, you must frequently inspect the outside of the container for signs of deterioration, discharges, or accumulation of oil inside diked areas.	☐ Yes ☐ No ☑ NA	☐ Yes ☐ No ☑ NA
	You must determine and document in the Plan the appropriate qualifications for personnel performing tests and inspections. 15	☐ Yes ☐ No ☑ NA	Yes No NA

¹⁴ Records of inspections and tests kept under usual and customary business practices will suffice

(7)	Leakage through defective internal heating coils controlled:		
	 Steam returns and exhaust lines from internal heating coils that discharge into an open watercourse are monitored for contamination, <u>OR</u> 	□Yes □No ☑NA	☐Yes ☐ No ☑NA
	 Steam returns and exhaust lines pass through a settling tank, skimmer, or other separation or retention system 	☐Yes ☐No ☑NA	☐Yes ☐No ☑NA
(8)		Yes No NA	Yes DNo DNA
	signal at a constantly attended operation or surveillance station, or audible air vent in smaller facilities; and pumping stati • Fast response sys- computers, telepu	stem for determining liquid te ilse, or direct vision gauges)	vel (such as digital and a person present to
		nd overall filling of bulk conta iid level sensing devices to e	
(9)	Effluent treatment facilities observed frequently enough to detect possible system upsets that could cause a discharge as described in §112.1(b)	☐Yes ☐No ☑NA	☐Yes ☐No ☑NA
(10)	Visible discharges which result in a loss of oil from the container, including but not limited to seams, gaskets, piping, pumps, valves, rivets, and bolts are promptly corrected and oil in diked areas is promptly removed	☑Yes ☐No ☐NA	☑Yes ☐No ☐NA
(11)	Mobile or portable containers positioned to prevent a discharge as described in §112.1(b).	☐Yes ☐No ☑NA	□Yes □No 図NA
	Mobile or portable containers (excluding mobile refuelers and other non-transportation-related tank trucks) have secondary containment with sufficient capacity to contain the largest single compartment or container and sufficient freeboard to contain precipitation	□Yes □No ☑NA	口Yes 口No 図NA
112.8(d)/112.12	(d)Facility transfer operations, pumping, and facility process		
(1)	Buried piping installed or replaced on or after August 16, 2002 has protective wrapping or coating	☑Yes ☐No ☐NA	⊠Yes □No □NA
	Buried piping installed or replaced on or after August 16, 2002 is also cathodically protected or otherwise satisfies corrosion protection standards for piping in 40 CFR part 280 or 281	☑Yes ☐No ☐NA	☑Yes ☐No ☐NA
	Buried piping exposed for any reason is inspected for deterioration; corrosion damage is examined; and corrective action is taken	☑ Yes ☐ No ☐ NA	☑Yes ☐No ☐NA
(2)	Piping terminal connection at the transfer point is marked as to origin and capped or blank-flanged when not in service or in standby service for an extended time	Yes ONO ONA	MYes □No □NA
(3)	Pipe supports are properly designed to minimize abrasion and corrosion and allow for expansion and contraction	☑Yes ☐No ☐NA	☑Yes ☐No ☐NA
(4)	Aboveground valves, piping, and appurtenances such as flange joints, expansion joints, valve glands and bodies, catch pans, pipeline supports, locking of valves, and metal surfaces are inspected regularly to assess their general condition	Yes No NA	☑Yes ☐No ☐NA
	Integrity and leak testing conducted on buried piping at time of installation, modification, construction, relocation, or replacement	Yes ONO ONA	☑Yes ☐No ☐NA
(5)	Vehicles warned so that no vehicle endangers aboveground piping and other oil transfer operations	☑Yes ☐No ☐NA	☑Yes ☐No ☐NA
Comments: 1 requirements.	There is underground piping running from the AST to the dispenser pum	ps. The plan adequately	addresses the above

ATTACHMENT A: SPCC FIELD INSPECTION AND PLAN REVIEW TABLE

Documentation of Field Observations for Containers and Associated Requirements

Inspectors should use this table to document observations of containers as needed.

	General Conition ¹ ad or Buried Tank	Storage Capacity (gal)	Type of Oil	Type of Containment/ Drainage Control	Overfill Protection and Testing & Inspections
Tank 4	acide is the surface	10,000	Unleaded		100 100 100 100 100 100 100 100 100 100
Tank 5	Steel vertical AST	10,000	#2 Diesel - Clear	Concrete containment dike	Tanks are equipped with sight gauges and high level alarms
Tank 6		10,000	Diesel – Dyed		7
55-gal drums	Steel drums	660	Motor oil and lubricating oil	Plastic/vinyl containment	Manual loading and unloading
prediction.	Term Agent	30,660	Gallons		and the second

ATTACHMENT B: SPCC INSPECTION AND TESTING CHECKLIST

Required Documentation of Tests and Inspections

Records of inspections and tests required by 40 CFR part 112 signed by the appropriate supervisor or inspector must be kept by all facilities with the SPCC Plan for a period of three years. Records of inspections and tests conducted under usual and customary business practices will suffice. Documentation of the following inspections and tests should be kept with the SPCC Plan.

			entation	N-4
	Inspection or Test	Present	Not Present	Not Applicable
12.7–Genera	I SPCC Requirements			
(d)	Integrity testing for bulk storage containers with no secondary containment system and for which an impracticability determination has been made			Lamana Lamana
(d)	Integrity and leak testing of valves and piping associated with bulk storage containers with no secondary containment system and for which an impracticability determination has been made			
(h)(3)	Inspection of lowermost drain and all outlets of tank car or tank truck prior to filling and departure from loading/unloading rack	V		and the same of th
(i)	Evaluation of field-constructed aboveground containers for potential for brittle fracture or other catastrophic failure when the container undergoes a repair, alteration, reconstruction or change in service or has discharged oil or failed due to brittle fracture failure or other catastrophe	anna d		M
k(2)(i)	Inspection or monitoring of qualified oil-filled operational equipment when the equipment meets the qualification criteria in §112.7(k)(1) and facility owner/operator chooses to implement the alternative requirements in §112.7(k)(2) that include an inspection or monitoring program to detect oil-filled operational equipment failure and discharges		[]	☑
112.8/112.12-	Onshore Facilities (excluding oil production facilities)			-
(b)(1), (b)(2)	Inspection of storm water released from diked areas into facility drainage directly to a watercourse			図
(c)(3)	Inspection of rainwater released directly from diked containment areas to a storm drain or open watercourse before release, open and release bypass valve under supervision, and records of drainage events		\square	П
(c)(4)	Regular leak testing of completely buried metallic storage tanks installed on or after January 10, 1974 and regulated under 40 CFR 112		П	Ø
(c)(6)	Regular integrity testing of aboveground containers and integrity testing after material repairs, including comparison records	図		
(c)(6), (c)(10)	Regular visual inspections of the outsides of aboveground containers, supports and foundations	図		
(c)(6)	Frequent inspections of diked areas for accumulations of oil	$\overline{\mathbf{v}}$		
(c)(8)(v)	Regular testing of liquid level sensing devices to ensure proper operation			
(c)(9)	Frequent observations of effluent treatment facilities to detect possible system upsets that could cause a discharge as described in §112.1(b)		D	\square
(d)(1)	Inspection of buried piping for damage when piping is exposed and additional examination of corrosion damage and corrective action, if present			V
(d)(4)	Regular inspections of aboveground valves, piping and appurtenances and assessments of the general condition of flange joints, expansion joints, valve glands and bodies, catch pans, pipeline supports, locking of valves, and metal surfaces			
(d)(4)	Integrity and leak testing of buried piping at time of installation, modification, construction, relocation or replacement			\square

This page left intentionally blank.

ATTACHMENT & PORMORES RECTION AND TENTINGS TO

ATTACHMENT C: SPCC CONTINGENCY PLAN REVIEW CHECKLIST

40 CFR Part 109-Criteria for State, Local and Regional Oil Removal Contingency Plans

D NA

If SPCC Plan includes an impracticability determination for secondary containment in accordance with §112.7(d), the facility owner/operator is required to provide an oil spill contingency plan following 40 CFR part 109, unless he or she has submitted a FRP under §112.20. An oil spill contingency plan may also be developed, unless the facility owner/operator has submitted a FRP under §112.20 as one of the required alternatives to general secondary containment for qualified oil filled operational equipment in accordance with §112.7(k).

109.5–I	Development and implementation criteria for State, local and regional oil removal contingency plans 15	Yes	No
(a)	Definition of the authorities, responsibilities and duties of all persons, organizations or agencies which are to be involved in planning or directing oil removal operations.		[\forall]
(b)	Establishment of notification procedures for the purpose of early detection and timely notification of an oil discharge including:	X	- Toronto
(1)	The identification of critical water use areas to facilitate the reporting of and response to oil discharges.		Y
(2)	A current list of names, telephone numbers and addresses of the responsible persons (with alternates) and organizations to be notified when an oil discharge is discovered.	Y	
(3)	Provisions for access to a reliable communications system for timely notification of an oil discharge, and the capability of interconnection with the communications systems established under related oil removal contingency plans, particularly State and National plans (e.g., National Contingency Plan (NCP)).		\mathbf{Y}
(4)	An established, prearranged procedure for requesting assistance during a major disaster or when the situation exceeds the response capability of the State, local or regional authority.	America	(Z)
(c)	Provisions to assure that full resource capability is known and can be committed during an oil discharge situation including:		Y
(1)	The identification and inventory of applicable equipment, materials and supplies which are available locally and regionally.	П	$\overline{\mathbf{N}}$
(2)	An estimate of the equipment, materials and supplies that would be required to remove the maximum oil discharge to be anticipated.		V
(3)	Development of agreements and arrangements in advance of an oil discharge for the acquisition of equipment, materials and supplies to be used in responding to such a discharge.		(
(d)	Provisions for well-defined and specific actions to be taken after discovery and notification of an oil discharge including:	V	
(1)	Specification of an oil discharge response operating team consisting of trained, prepared and available operating personnel.		$\mathbf{\nabla}$
(2)	Pre-designation of a properly qualified oil discharge response coordinator who is charged with the responsibility and delegated commensurate authority for directing and coordinating response operations and who knows how to request assistance from Federal authorities operating under existing national and regional contingency plans.		Ś
(3)	A preplanned location for an oil discharge response operations center and a reliable communications system for directing the coordinated overall response operations.		V
(4)	Provisions for varying degrees of response effort depending on the severity of the oil discharge.		S
(5)	Specification of the order of priority in which the various water uses are to be protected where more than one water use may be adversely affected as a result of an oil discharge and where response operations may not be adequate to protect all uses.		\square
(e)	Specific and well defined procedures to facilitate recovery of damages and enforcement measures as provided for by State and local statutes and ordinances.		$\mathbf{\nabla}$

Note: The Contingency Plan included in the Plan Attachments but is not required so deficiencies in the Contingency Plan are not considered Plan deficiencies.

¹⁵ The contingency plan should be consistent with all applicable state and local plans, Area Contingency Plans, and the NCP.

This page left intentionally blank.

The one of the control of the contro

ATTACHMENT D: TIER II QUALIFIED FACILITY CHECKLIST

Charles	
V.	
14.1	NA
E Messa C	13/7

	TED FACILITY PLAN REQUIREMENTS —40 CFR 112.6(b)	
	Plan Certification: Owner/operator certified in the Plan that:	ПYes ПNo
and the second second	He or she is familiar with the requirements of 40 CFR part 112	☐Yes ☐No ☐
7	He or she has visited and examined the facility ¹⁶	☐Yes ☐No ☐
4.0	The Plan has been prepared in accordance with accepted and sound industry practices and standards and with the requirements of this part	Пуев П № П
	Procedures for required inspections and testing have been established	LI Yes LI No L
	He or she will fully implement the Plan	LIYes LINO L
	The facility meets the qualification criteria set forth under §112.3(g)(2)	Carlo
1.00	The Plan does not deviate from any requirements as allowed by §§112.7(a)(2) and 112.7(d), except as described under §112.6(b)(3)(i) or (ii)	L Yes L No L
(viii)	The Plan and individual(s) responsible for implementing the Plan have the full approval of management and the facility owner or operator has committed the necessary resources to fully implement the Plan.	Clyes ClNo C
112.6(b)(2)	Technical Amendments: The owner/operator self-certified the Plan's technical amendments for a change in facility design, construction, operation, or maintenance that affected potential for a §112.1(b) discharge	Пуев П No П
If YES	 Certification of technical amendments is in accordance with the self-certification provisions of §112.6(b)(1). 	Пуев Пио П
(i)	A PE certified a portion of the Plan (i.e., Plan is informally referred to as a hybrid Plan)	Пуев П № П
If YES	The PE also certified technical amendments that affect the PE certified portion of the Plan as required under §112.6(b)(4)(ii)	Пуев П № П
(ii)	The aggregate aboveground oil storage capacity increased to more than 10,000 U.S. gallons as a result of the change	Пуев ПNо П
If YES	The facility no longer meets the Tier II qualifying criteria in §112.3(g)(2) bed it exceeds 10,000 U.S. gallons in aggregate aboveground storage capac	ause ity.
	The owner/operator prepared and implemented a Plan within 6 months following the change and had it certified by a PE under §112.3(d)	Пуев П № П
112.6(b)(3)	Plan Deviations: Does the Plan include environmentally equivalent alternative methods or impracticability determinations for secondary containment? Identify the alternatives in the hybrid Plan:	☐Yes ☐No ☐
	Environmental equivalent alternative method(s) allowed under §112.7(a)(2);	TYes TNo D
	Impracticability determination under §112.7(d)	☐Yes ☐No ☐
112.6(b)(4)	 For each environmentally equivalent measure, the Plan is accompanied by a written statement by the PE that describes: the reason for nonconformance, the alternative measure, and how it offers equivalent environmental protection in accordance with §112.7(a)(2); 	☐Yes ☐No [
	For each secondary containment impracticability determination, the Plan explains the reason for the impracticability determination and provides the alternative measures to secondary containment required in §112.7(d) AND	☐Yes ☐No ☐
(i)		
(A)	AN A	☐Yes ☐No [
(B)		Yes ONo
(C)		☐Yes ☐No [
omments: Th	nis is not a Tier II Qualified facility.	_

 $^{^{\}rm 16}$ Note that only the person certifying the Plan can make the site visit

ATTACHMENT E: ADDITIONAL COMMENTS

The facility is a wholesale and retail supplier of petroleum products. Petroleum products are stored in three aboveground storage tanks that are within a concrete secondary containment and in 55-gallon drums inside the facility's building. The total oil storage capacity is 30,660 gallons. The facility is open 24 hours per day to customers for fueling purposes. Fueling is conducted at the facility's dispenser island. Site drainage is to the south-southeast where an unnamed creek is located at the property boundary, which flows to Lick Fork. Spill response materials (absorbent, etc.) are located inside the facility building. The SPCC plan does not discuss general secondary containment. The SPCC plan should be revised to include a discussion of general secondary containment measures appropriate for the facility. Secondary containment drainage logs were available through May 2015 but no records are available since that time. Containment drainage logs need to be resumed and maintained. Tank integrity testing is discussed in the plan but no details regarding the type and time of tests are provided. Integrity testing records were also not available during the site visit. General housekeeping appeared good and there was no evidence of unaddressed spills or releases at the facility.

ATTACHMENT F: PHOTO DOCUMENTATION NOTES

Photo log	Photographer Name	Time Photo Taken	Compass Direction	Description	
1	Paul Doherty	AM 5/5/2016	North	View of MFA Oil Petro Card facility from South 24th Street in Lexington, Missouri.	
2	Paul Doherty	AM 5/5/2016	Northeast	View of oil storage tanks within secondary containment.	
3	Paul Doherty	AM 5/5/2016	Northeast	View of oil storage tanks within secondary containment.	
4	Paul Doherty	AM 5/5/2016	North	View of drain from secondary containment.	
5	Paul Doherty	AM 5/5/2016	West	View of facility building with various-sized containers of oil, including 55-gallon drums, and oil spill absorbent materials.	
6	Paul Doherty	AM 5/5/2016	West	View of facility building with various-sized containers of oil, including 55-gallon drums, and oil spill absorbent materials.	
7	Paul Doherty	AM 5/5/2016	Northwest	View of 55-gallon drums of oil inside secondary containment.	
8	Paul Doherty	AM 5/5/2016	South	View of dispenser area. Site drainage is to the southeast. No general secondary containment was present.	

A STATE OF THE STA

the family remain magazine the factor can

State of the state

and a second

Control March

Palma Ciclement

De terristru


The first of the register of great and analysis of the second of


garan karan ka

र के क्षेत्र है । यह किस् के के के के के किस के

and the first of the second of


Tation and the constitution








20.7		
46.		
1.7		
	A STATE	
		r v sakt s
W		
		1
All the		



					ě.
			4.		(#) M
				Ce.	Ser.
		and the second		The said of the said	4
				9	
			tion of the second		
A AMERICAN STATE OF THE STATE O				A.	
					u ·
				in Jake	
					, per
					• • • • • • • • • • • • • • • • • • • •
				W N 	
				The same	
		1.30.30			
					^
	7:00		Wash.		The same of the sa
			Service Control		
		The said			
The same of the sa					



	Sea.		
			And the second of the second o
			8. 0
and the second			
	K.		




Photo: #1 Site: MFA Oil Petro Card Station, Lexington, MO Date: 5/5/2016 Time: AM Direction: North Photographer: Paul Doherty, EPA Witness: Jeff Pritchard, EPA Description: View of MFA Oil Petro Card Station from South 24th Street in Lexington, Missouri.




Photo: #2 Site: MFA Oil Petro Card Station, Lexington, MO Date: 5/5/2016 Time: AM Direction: Northeast Photographer: Paul Doherty, EPA Witness: Jeff Pritchard, EPA Description: View of oil storage tanks within secondary containment.

			10.90	
		Ĩ, Ã,	and the second	
ile S				

•



Photo: #3 Site: MFA Oil Petro Card Station, Lexington, MO Date: 5/5/2016 Time: AM Direction: Northeast Photographer: Paul Doherty, EPA Witness: Witness: Jeff Pritchard, EPA Description: View of oil storage tanks within secondary containment.



Photo: # 4 Site: MFA Oil Petro Card Station, Lexington, MO Date: 5/5/2016 Time: AM Direction: North Photographer: Paul Doherty, EPA Witness: Witness: Jeff Pritchard, EPA Description: View of drain from secondary containment.






Photo: # 5 Site: MFA Oil Petro Card Station, Lexington, MO Date: 5/5/2016 Time: AM Direction: West Photographer: Paul Doherty, EPA Witness: Witness: Jeff Pritchard, EPA Description: View of facility building with various-sized containers of oil, including 55-gallon drums, and oil spill absorbent materials.






Photo: #6 Site: MFA Oil Petro Card Station, Lexington, MO Date: 5/5/2016 Time: AM Direction: West Photographer: Paul Doherty, EPA Witness: Witness: Jeff Pritchard, EPA Description: View of facility building with various-sized containers of oil, including 55-gallon drums, and oil spill absorbent materials.



Bengara Bengaran Januaran King yang palaminan seria Kingaran Kingaran Kingaran Bengaran Kingaran Kingaran Januaran Kingaran Seria seria seria Kingaran Kingaran Kingaran Seria seria seria seria seria seria seria seria Bengaran Seria seria






Photo: #7 Site: MFA Oil Petro Card Station, Lexington, MO Date: 5/5/2016 Time: AM Direction: Northwest Photographer: Paul Doherty, EPA Witness: Witness: Jeff Pritchard, EPA Description: View of 55-gallon drums of oil inside secondary containment.




Photo: #8 Site: MFA Oil Petro Card Station, Lexington, MO Date: 5/5/2016 Time: AM Direction: South Photographer: Paul Doherty, EPA Witness: Witness: Jeff Pritchard, EPA Description: View of dispenser area. Site drainage is to the southeast.